

**OFFICE OF THE STATE FIRE MARSHAL  
STATE OF ILLINOIS**

Statute, Rule or Standard Policy Interpretation:

Policy Number: 10-PCS-005    Deadline for retrofitting to meet new requirements for emergency electrical shutoff switches at Attended Self Service, Unattended Self Service, Fleet Vehicle, Full Service, and Marine Motor Fuel Dispensing Facilities    Effective Date: November 10, 2010

---

Title: 41 Ill. Adm. Code  
Part: 175  
Part Title: Technical Requirements For Underground Storage Tanks and the Storage, Transportation, Sale and Use of Petroleum and Other Regulated Substances  
Subpart: B  
Subpart Title: Motor Fuel Dispensing Facility Requirements  
Section Number: 175.210; 175.220; 175.230; 175.240; 175.250  
Section Title: Attended Self-Service Motor Fuel Dispensing Facilities and Islands; Unattended Self-Service Motor Fuel Dispensing Facilities and Islands; Fleet Vehicle Motor Fuel Dispensing Facilities; Full Service Motor Fuel Dispensing Facilities and Islands; Marine Motor Fuel Dispensing Facilities

---

Purpose: This instruction provides for current policy and guidance to ensure uniform enforcement of 41 Ill. Adm. Code 175.210 through 175.250.

Scope: Statewide

Current Code: Section 175.210 governing attended self service motor fuel dispensing facilities and islands provides that facilities must retrofit their facilities to meet new requirements for emergency electrical shutoff switches by September 1, 2013. 41 Ill. Adm. Code 175.210(d)(4). Sections 175.220, 175.230, 175.240 and 175.250 further state that the requirements applicable to attended self-service facilities also apply to these other types of motor fuel dispensing facilities subject to the additions or modifications provided in those other sections. 41 Ill. Adm. Code 175.220, 175.230, 175.240 and 175.250.

Policy Interpretation: All categories of existing motor fuel dispensing facilities regulated by OSFM as of September 1, 2010 shall have until September 1, 2013 to retrofit their facilities to meet new requirements for emergency electrical shutoff switches. New facilities and dispensing islands installed or constructed after September 1, 2010 shall meet the emergency electrical shutoff switch requirements of Part 175, Subpart B that are effective as of the date of installation.

Repealed Date:

Superseded: