

Area of Opening (ft²) Determined by Window Dimensions (Shaded Areas Comply with LSC required 5.7 ft²)

LSC Minimum: 20" Wide x 24" High
AND 5.7 SQUARE FEET

		WIDTH OF WINDOW (IN INCHES)																													
		20	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36														
HEIGHT OF WINDOW (IN INCHES)	Inches	20	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36														
24	24	3.33	3.67	3.83	4.00	4.17	4.33	4.50	4.67	4.83	5.00	5.17	5.33	5.50	5.67	5.83	6.00														
	25	25	3.47	3.82	3.99	4.17	4.34	4.51	4.69	4.86	5.03	5.21	5.38	5.56	5.73	5.90	6.08	6.25													
		26	26	3.61	3.97	4.15	4.33	4.51	4.69	4.88	5.06	5.24	5.42	5.60	5.78	5.96	6.14	6.32	6.50												
			27	27	3.75	4.13	4.31	4.50	4.69	4.88	5.06	5.25	5.44	5.63	5.81	6.00	6.19	6.38	6.56	6.75											
				28	28	3.89	4.28	4.47	4.67	4.86	5.06	5.25	5.44	5.64	5.83	6.03	6.22	6.42	6.61	6.81	7.00										
					29	29	4.03	4.43	4.63	4.83	5.03	5.24	5.44	5.64	5.84	6.04	6.24	6.44	6.65	6.85	7.05	7.25									
						30	30	4.17	4.58	4.79	5.00	5.21	5.42	5.63	5.83	6.04	6.25	6.46	6.67	6.88	7.08	1.72	0.43								
							31	31	4.31	4.74	4.95	5.17	5.38	5.60	5.81	6.03	6.24	6.46	6.67	6.89	7.10	7.32	7.53	7.75							
								32	32	4.44	4.89	5.11	5.33	5.56	5.78	6.00	6.22	6.44	6.67	6.89	7.11	7.33	7.56	7.78	8.00						
									33	33	4.58	5.04	5.27	5.50	5.73	5.96	6.19	6.42	6.65	6.88	7.10	7.33	7.56	7.79	8.02	8.25					
										34	34	4.72	5.19	5.43	5.67	5.90	6.14	6.38	6.61	6.85	7.08	7.32	7.56	7.79	8.03	8.26	8.50				
											35	35	4.86	5.35	5.59	5.83	6.08	6.32	6.56	6.81	7.05	7.29	7.53	7.78	8.02	8.26	8.51	8.75			
												36	36	5.00	5.50	5.75	6.00	6.25	6.50	6.75	7.00	7.25	7.50	7.75	8.00	8.25	8.50	8.75	9.00		
													37	37	5.14	5.65	5.91	6.17	6.42	6.68	6.94	7.19	7.45	7.71	7.97	8.22	8.48	8.74	8.99	9.25	
														38	38	5.28	5.81	6.07	6.33	6.60	6.86	7.13	7.39	7.65	7.92	8.18	8.44	8.71	8.97	9.24	9.50
															39	39	5.42	5.96	6.23	6.50	6.77	7.04	7.31	7.58	7.85	8.13	8.40	8.67	8.94	9.21	9.48
40																40	5.56	6.11	6.39	6.67	6.94	7.22	7.50	7.78	8.06	8.33	8.61	8.89	9.17	9.44	9.72
	41															41	5.69	6.26	6.55	6.83	7.12	7.40	7.69	7.97	8.26	8.54	8.83	9.11	9.40	9.68	9.97
		42														42	5.83	6.42	6.71	7.00	7.29	7.58	7.88	8.17	8.46	8.75	9.04	9.33	9.63	9.92	10.21
			43													43	5.97	6.57	6.87	7.17	7.47	7.76	8.06	8.36	8.66	8.96	9.26	9.56	9.85	10.15	10.45
				44												44	6.11	6.72	7.03	7.33	7.64	7.94	8.25	8.56	8.86	9.17	9.47	9.78	10.08	10.39	10.69
					45											45	6.25	6.88	7.19	7.50	7.81	8.13	8.44	8.75	9.06	9.38	9.69	10.00	10.31	10.63	10.94
						46										46	6.39	7.03	7.35	7.67	7.99	8.31	8.63	8.94	9.26	9.58	9.90	10.22	10.54	10.86	11.18
							47									47	6.53	7.18	7.51	7.83	8.16	8.49	8.81	9.14	9.47	9.79	10.12	10.44	10.77	11.10	11.42
								48								48	6.67	7.33	7.67	8.00	8.33	8.67	9.00	9.33	9.67	10.00	10.33	10.67	11.00	11.33	11.67

Operable from inside without use of tools, keys, or special effort. Bottom of the opening no more than 44 in. above floor. (Unless permanent platform is present)																	
Acceptable where one of the following criteria are met:																	
-1	The window shall be within 20 ft of grade.																
-2	The window shall be directly accessible to fire department rescue apparatus as approved by the authority having jurisdiction.																
-3	The window or door shall open onto an exterior balcony.																
-4	The window shall have a sill height below the adjacent ground level and shall be provided with a window well meeting LSC criteria.																